


**Melinda L. McGrath**  
Deputy Executive Director/  
Chief Engineer

**Brenda Znachko**  
Deputy Executive Director/  
Administration



**Larry L. "Butch" Brown**  
Executive Director

**Steven K. Edwards**  
Director  
Office of Intermodal Planning

**Willie Huff**  
Director  
Office of Enforcement

---

*Contract Administration Division / P.O. Box 1850 / Jackson, Mississippi 39215-1850 / Telephone (601) 359-7700 / FAX (601) 359-7732 / GoMDOT.com*

---

**To: ALL POTENTIAL BIDDERS**

**Date: 08/20/2009**

**RE: Call No. 11, STP/IM-0055-02(210) / 105533301 & 302 – Holmes County**

Bidders are advised that the following is to clarify some possible misunderstanding of the meaning of Section 44 41 13, Package Plant Sewage Treatment System, in Special Provision No. 907-242-11.

Criteria stated in paragraph 1.02, Parts A, B, & D, and 2.04, Part A, Numbers 4 and 5 of Section 44 41 13 shall be governing factors in providing Equalization Tankage sizes for this Project. Dimensions of each Chamber for Equalization Tank are not required to be as stated in Paragraph 2.04 of 10.5 ft. dia. X 15.80 ft. D. If the Contractor elects to adjust the dimensions of the tankage to other than that specified in the contract documents or shown on the contract drawings, the design submission requirements of Section 2.01, Part B, will apply.

Your formal acknowledgment of receipt of this notification will be entered into our records and indicates your understanding of the requirements for the Package Plant Sewage Treatment System on this project, and that you have bid accordingly. Please sign this sheet and return by FAX to MDOT Contract Administration Engineer at 601-359-7732.

  
for Melinda L. McGrath, P.E.  
Chief Engineer / Deputy Executive Director

\_\_\_\_\_  
Contractor

\_\_\_\_\_  
Authorized Signature