

Melinda L. McGrath
Interim Executive Director/
Chief Engineer

Jackie Duckworth
Deputy Executive Director/
Administration



Charles R. Carr
Director
Office of Intermodal Planning

Willie Huff
Director
Office of Enforcement

Contract Administration Division / P.O. Box 1850 / Jackson, Mississippi 39215-1850 / Telephone (601) 359-7700 / FAX (601) 359-7732 / GoMDOT.com

To: ALL POTENTIAL BIDDERS

Date: 07/22/2011

RE: Call No. 02, STP-0022-02(051) / 106207301 -- Neshoba County

Bidders are advised that following the 3-inch milling from Station 228+36 to 519+50 in accordance with the Scope of Work, a 1½" lift of 12.5-mm, MT, HMA/WMA, Leveling, will be placed. Traffic will be allowed on the leveling lift and the surface lift of 1½" of 9.5-mm, MT, HMA/WMA, will be placed under traffic.

Bidders are advised that the milling depth at county roads from Station 228+36 to 519+50 shall be 1½" and shall be overlaid with 1½" of 9.5-mm, MT, HMA/WMA mix. The limits of the 1½-inch milling are as shown on the County Roads detail from the edge on the 28-foot mainline pavement width to the End of State Maintenance. Traffic will be able to run on the milled surface at these County Roads for a maximum of seven (7) days, or as directed by the Engineer. Milling will only be required to the face of guard rails. Driveway pads will be milled straight through and only replaced if they are in bad condition as determined by the Engineer.

Bidders are further advised that the material removal (milling), referenced in the second paragraph on Page 63 of the Scope of Work, signifies ONLY the material necessary to prevent ponding of water.

Bidders are further advised that the pay item description for Line No. 0250, 409-A002, Geotextile Fabric For Underseal, Type V, is in error. The correct type of fabric is **Type IV**.

DO NOT CHANGE THE PAY ITEM DESCRIPTION LISTED ON THE PROPOSAL BIDSHEETS. Total bid for Line No. 0250, 409-A002, Geotextile Fabric For Underseal, Type V, must be based on a unit bid price for **Type IV Geotextile Fabric** and extended using the indicated quantity.

Your formal acknowledgment of receipt of this notification will be entered into our records and indicates your understanding the above paving sequences, construction details, and type of geotextile fabric on this project, and that you have bid accordingly.

All Potential Bidders

07/22/2011

Page 2

Please have an authorized representative of your company sign this page and return by FAX to 601-359-7732.



Melinda L. McGrath, P.E.
Interim Executive Director / Chief Engineer

Contractor

Authorized Signature

RE: Call No. 02, STP-0022-02(051) / 106207301 -- Neshoba County