

Call 18 Utility improvements and site work for the shop building at the MDOT Materials Laboratory, known as State Project No. LWO-9023-25(002)/ 502350303 in Hinds County.

Q1. Do you require the steel pipe to be coated ID and/or OD?

A1. The steel pipe shall be coated both inside and outside.