

Call 10 Mill & Overlay approximately 3 miles of SR 182 from Stark Road to MSU Research Park, known as State Project No. MP-1182-53(002) / 304796301 in Oktibbeha County.

- Q1. 1. Does the Curb (Doweled) detail in the upper right portion of sheet SD-2 provide the method of construction details for line item #609-B005 Concrete Curb, Special Design Doweled? 2. Additionally, is there a particular angle that the curb is to be cut as noted on sheet SQ-1, note #3?
- A1. 1. Yes 2. The angle of cut will follow the slope of the gutter.
- Q2. Is the intended use for the 203-EX018 Borrow Excavation pay item for fill material under new walks and for backfill of curbs?
- A2. It will be used as backfill for islands, sidewalks and curbs as directed by the Engineer.
- Q3. Does pay item 503-C007 Saw Cut, Full Depth include the pavement cutting required for the new island installation & angular cutting required for the new Doweled Curb (pay item #609-B005)?
- A3. Pay item 503-C007 Saw Cut includes the quantity for island installation; however, the angular cut on the curb is absorbed in pay item 202-B038 Removal of Curb.
- Q4. Concerning pay item #613-D004 Adjustment of Inlet: - based on comparing the drawings to the current field conditions, it appears that some inlets may need to be converted from a grate inlet to a curb inlet to remain in their current location or vise-versa depending on the new curb line; will this conversion be covered in a supplemental agreement or should the bidders include these possible conversions in the bid item? – Additionally, it appears that some inlets may need to be relocated if not converted as described above; in this case, we assume relocating an inlet would be covered in an SA – is this correct?
- A4. The bid for pay item Adjustment of Inlet should not include costs for converting or relocating inlets.
- Q5. 1. What joint detail will we be using for the Cleaning & Filling Joints pay item? 2. Are you sure the 47,000 Linear Feet of Sawing & Sealing is a good quantity?
- A5. 1. The Contractor should bid as per section 413.03.2.2 of the 2004 Standard Specifications of Road and Bridge Construction. 2. Yes