

Call 18 Overlay approximately 8 miles of SR 26 from Steven Moore Road to 450 feet West of SR 15, known as State Project No. MP-6026-66(010) / 304812301 in Stone County.

- Q1. 1. On page 41 of the specifications Section 904 C there are four patch locations identified that require backfilling with 19mm Asphalt ST mixture. There is no pay item for this. Where is this cost to be included? 2. In Section 904 D it states “..Privately owned entrances shall be surfaced a distance of 10 feet...” Some of the private entrances are currently gravel entrances. Are we to pave the gravel entrances with Ultra-thin Asphalt pavement?
- A1. 1. A pay item for 19mm Asphalt will be added by addendum. 2. Driveways that are existing asphalt driveways will be resurfaced; however, gravel driveways may not require surfacing, but will be handled as directed by the Engineer.
- Q2. Is there a certain quantity set aside for ½” UHWA lift to be used as directed by the engineer? What is the width of the existing roadway?
- A2. A uniform leveling lift will be required and the contractor should reference the typical section found at the following website for more information:
[http://ftp.mdot.state.ms.us/ftp/Construction/District 6/June Letting 2013/](http://ftp.mdot.state.ms.us/ftp/Construction/District%206/June%20Letting%202013/)

<http://ftp.mdot.state.ms.us/ftp/Construction/District%202/April%20Letting%202013>