Call 02 Overlay approximately 11 miles of the Southbound Lane of US 49 from SR 149 in Magee to SR 149 in Mendenhall, known as Federal Aid Project No. STP-0008-02(101) / 106698301 in Simpson County.

- Q1. 1-Is tack coat absorbed? 2-Will paving be required under and behind existing guardrail?
  3-Will +/- 20 rubber/plastic curb pieces that are in Rt. crossover in milled section be replaced after paving by contractor?
- A1. 1. No. See Addendum No. 12. Yes, see Note 15 in General Notes. 3. No, D7 Maint. will remove and replace these.