

Call 13 Scrub Seal on SR 403 & SR 404, known as State Project Nos. MP-1000-78(071) / 305168301 & 302 in Webster County.

Q1. What is the permanent stripe width 4 or 6 inch?

A1. Six (6) inch

Q2. Will you be adding do not pass/pass with care signs to this job? It calls for them but don't have the totals for them in the proposal.

A2. See the addendum for this project.

Q3. Could you provide quantities for passing zone signs?

A3. See QandA # 2.