

Call 05 Overlay I-59 Loop Ramps at US 49 with High Friction Surface Treatment, known as Federal Aid Project No. HSIP-0059-01(114) / 106818301 in Forrest County.

- Q1. **1.** Although there are not prints with this project, it appears the mill and fill asphalt on the Northeast loop will get covered with high friction. It is recommended that all new asphalt and concrete be allowed to cure for 30 days prior to placing HFST. The contract only allows for 20 working days. Can you please clarify? **2.** Can you also clarify that Granite or Gravel is allowed as a high friction ramp as written in the specification?
- A1. **1.** Time will not be charged during the 30-day cure period for HFST provided all other work is completed to the satisfaction of the Engineer. **2.** The aggregate can be crushed Calcium Bauxite, Granite or gravel as per special provision 907-410-8 and subsection 907-410.02.2.