

Call 16 Overlay approximately 6 miles of SR 42 from SR 63 East, known as State Project No. MP-6042-21(009) / 305494301 in Greene County.

Q1. Will 825B Crushed Stone be allowed as shoulder material or does the gradation have to meet the 610 Crushed Stone gradation?

A1. No, Size 610 Crushed Stone is required.