

Call 01 Construction necessary to install a traffic signal on SR 63 at SR 614, known as Federal Aid Project No. HSIP-0002-01(048) / 106627301 in Jackson County.

Q1. Only (8) of the signalization items are designated as "specialty items". Can more of the signalization items be added?

A1. No

Q2. Can 2" roll pipe be used for the 2" Conduit that runs from the pullboxes at the stop bars down to the pullboxes at the "Prepare to Stop" signs?

A2. Yes, but it will be paid for as conduit.