

**Call 03 Intersection improvements on SR 12 at Russell Street in Starkville, known as
Federal Aid Project No. STP-0018-03(022) / 106954301 in Oktibbeha County.**

Q1. Sheet 19(EQ-5) note 1 states that the luminaires for the traffic signal poles shall be LED, but it refers to sheet 2006 (TSD-6) which shows a 250 watt HPS, which one does it need to be?

A1. LED luminaires for the traffic signal poles are required. The reference to 250 watt HPS on sheet 2006 (TSD-6) should be disregarded.

Q2. Will the contractor be able to start the project before the notice to proceed date?

A2. No