

**Call 01 Slope Correction on U.S.45 near Wheeler Grove Road, known as Federal Aid
Project No. HSIP-0002-08(019) / 107112301 in Alcorn County.**

Q1. Are there any retaining walls, and if so, how many feet?

A1. There are no retaining walls required.