

Call 05 I-20/SR 15 Interchange Lighting, known as Federal Aid Project No. STP-0020-02(090) / 107007301 in Newton County.

Q1. My question concerns the low and high mast LED lighting fixtures. I know the specification is designed around the Acuity Holophane fixture package. Is there another MDOT approved package or is it locked to this brand?

A1. MDOT will consider other manufacturers. Equipment must meet the requirements of Special Provision 907-723-2. Photometric data will need to be supplied to show that proposed fixtures will meet the average maintained lighting level and uniformity as shown on Sheet 4001. The proposed equipment must provide the required coverage using the current pole locations.