

Call 09 Grade Bridge on 2 Lanes of SR 15 from SR 76 to the Pontotoc/Union County Line, known as Federal Aid Project No. STP-0022-04(040) / 102607301 in Pontotoc County.

Q1. **1.** Where is the 240 LF of temporary construction fence being constructed? **2.** Also, there is no 907-607 SP in the specifications for the fence?

A1. **1.** The temporary fence is to close off the Tanglefoot Trail at the old railroad along the ROW on both sides. **2.** Reference the attached link for specification: <https://file-exchange.mdot.state.ms.us/dl/?f=75aa1c7b84bd41d97bcff19548dd67ef3280cf58>

Q2. We would like to request that the Mesa MSE block wall system which is on the MDOT QPL, be an acceptable wall type for use on this project?

A2. Yes, the use of this system is acceptable for this project.

Q3. Please verify Class "AA" Bridge Concrete quantity for the superstructure of Bridge B. Plan quantity seems higher than the takeoff quantity.

A3. See the addendum to the project.

Q4. **1.** There is currently a small detention pond with outlet structure located underneath proposed Bridge B. Is this pond to remain or will it be drained and backfilled? If the pond is to remain, will the contractor be allowed to drain this pond during pile driving? **2.** Just north of Bridge B there it appears there is an old gas station site. Are there any underground tanks at this site? **3.** Notice to Bidders 6018 requires all substructure work to be completed from July 1 to August 31. Is bridge cap and MSE wall construction included in this restriction?

A4. **1.** This area will be drained and backfilled. **2.** No **3.** See the addendum to the project.

Q5. The plans show the 7 message boards on the Tanglefoot Trail during the July 1-August 31 time when work is performed at the trail, is this the only time they will be used or should they be figured the entire length of the job?

A5. This is the only time. Just during the actual closure.

Q6. What work is necessary on this project, the description says Grade Bridge?

A6. The description should read Grading and Bridge work.