

Call 14 Slide Repair & Erosion/Surface Drainage Remediation on I-55, known as Federal Aid Project No. IM-0055-04(097) / 106531301 in Desoto County

Q1. Can the piling on this project be installed using a vibratory hammer?

A1. Yes, but the Contractor still has the responsibility to drive the H-piles to the required tip elevations.