

Call 13 Building, Renovating, and Lot work of the Foxworth Project Office, known as State Project Nos. BWO-7149-46(001), BWO-7079-46(003), and LWO-7061-46(003) / 502689301, 302 & 303 in Marion County.

Q1. Section 907-107.14.2.2- Railroad Protective: This section is requiring supplementary coverage for railway easements and property. There is an adjacent railway but the scope of work does not include work on railway right of way or property. Including coverage costs for this seems wasteful of funds. What is the requirement for this project?

A1. The Railroad protective doesn't apply to this project.

Q2. Is there an Addendum Plan Sheet #3?

A2. No, the addendum revised only plan sheets Nos. 2, 4-8, 12, & 25.1.

Q3. Per sheet C1.5, we will have to cut and remove the existing asphalt for the installation of 2-2" conduit and new sewer line and the removal of the existing sewer line. Is this part of the asphalt line item (0220 & 0230)? If not, where do we put it?

A3. It should be absorbed in pay item 907-242-PP001 (Water and Sewer Improvements, Per Plans).