

Call 10 Bridge Repair on SR 69 Over McCrary Creek Bridge No. 11.8, known as State Project No. EXB-0068-01(008) / 107139303 in Lowndes County.

Q1. Where can the contractor have access to the project?

A1. The Contractor is advised that access to the work site shall be from the south side of the bridge structure. Should the Contractor choose to access the work site from the north, additional coordination with the Railroad will be required.

Q2. Will there be a railroad requirement for this project?

A2. Yes, Notice to bidders 1727 with supplement was inadvertently left out of the proposal but can be found at the following website and the specification will be added officially by Class IV Supplemental Agreement. **The contractor shall include the additional cost for the railroad insurance in your bid as absorbed cost.**

<https://file-exchange.mdot.state.ms.us/dl/?f=2751d98ab3cca58c2c11339c8ee35ba5bafdc0e9>

Q3. Does Notice to Bidders No. 4300 (Exposure to Severe Sulfate Areas Below Ground Level) apply to all bridge substructure concrete that is below ground in addition to the items of work listed?

A3. Yes