

**Call 07 District 5 Bearing Replacement, known as Federal Aid Project Nos. BR-9999-05(019) / 1070193040 & 3041 in Lauderdale and Newton Counties.**

Q1. The Cap Cleaning note on Page 66 says to clean the caps to the "satisfaction of the Engineer." What does that mean? Can we have some clarification as to what the intent or requirement is here? Do we just sweep off any debris? Do they have to be washed? Sandblasted?

A1. All large debris shall be removed by hand. All other debris (dirt & rust) shall be removed by pressuring washing the bent caps to the satisfaction of the Project Engineer. The pressure washer shall be able to maintain 3,500 psi of pressure.

Q2. We do not have enough information about these structures to put together a proposal. Can we at least have some beam details? A section showing the deck thickness and wall section? The dimensions of the existing caps? We have to be able to determine the loads we are jacking and without any as-built information it would just be a guess.

A2. Reference the below link:

<https://file-exchange.mdot.state.ms.us/dl/?f=f71cb8552370c6c211c8f1ca0aad85f773a56d0e>