

**Call 01 Renovation of the Existing District Six Shop and Minor Site Improvements, known as State Project Nos. BWO-6211-18(003) / 502889301 & LWO-6017-18(006) / 502889302 in Forrest County.**

Q1. I would like to see if Pinnacle Structures is an acceptable Metal Building Manufacturer for this project. I have a certification packet that I could email for approval if needed.

A1. Prior to bid, only the manufacturers listed in Section 13 34 19 (page 486) are approved for use.

Q2. **1.** I proposed using another metal building manufacturer, but I have not heard whether that is possible. Please let me know as soon as possible so I can get those guys working on this project. **2.** Also, at the pre-bid, there was a revised set of plans. Do we have to purchase the revised set?

A2. **1.** See QandA #1 **2.** No, an upcoming addendum will be issued to provide the revised plans.

Q3. Will you clarify what bid item that the over excavate and fill show on sheet C500/1.0 should be included in relating to pavement detail.

A3. It is to be included in the pay item for site grading.

Q4. Clarify exactly what all is included in bid item 907-601-B001, 835 cubic yard class":B" structural steel, Minor structures per plans.

A4. See the addendum to the project.

Q5. I could not find a spec section addressing the site fire protection, domestic water and sanitary piping. I could also not find information on the compressed air hose reels and who provides them.

A5. See the addendum to the project.

Q6. In the specs it calls for vinyl coated chain link fence. In the pictures on page AD106 it shows to be galvanized chain link fence with black slats. Which one do you want? The galvanized chain link or the vinyl coated?

A6. The chain link fence with black slats goes outside the building along the South Property Line. The fence components are described in the Summary of Quantities on Sheet Number 3, with pay items 607-B041 thru 907-607-PP007. The vinyl coated chain link partition inside the building is shown on the floor plans & specified in Section 10 22 14.