

Call 02 Construction of Maintenance Area Headquarters and Support Buildings at Louisville, known as State Project Nos. BWO-1192-80(001), BWO-1193-80(001), BWO-1194-80(001), & LWO-1063-80(001) / 502893301, 302, 303, & 304 in Winston County.

Q1. On sheet 4 @retaining wall systems you have 800 SF of wall. How is this SF figured using typical Wall Section on sheet 16? Please clarify

A1. The retaining wall quantity has been revised, see the addendum to the project.

Q2. Are the Bottom of Wall spot elevations shown on C400 the point where the retaining wall meets the footing or where the finished grade meets the retaining wall?

A2. The Bottom of Wall spot elevations shown on C400 are the elevations where the finished grade meets the wall. The actual bottom of wall / top of footing elevation will be at least one foot lower, as shown in the retaining wall section on sheet C701. The retaining wall quantity has been revised via addendum to take this into account.

Q3. Section 093113 - Ceramic Tile. The section shows 12x24 for the floor and wall and an accent glass tile. However, there is not a tile manufacture or style selected for none of the tile. There are thousands of tiles to choose from. There needs to be a floor, wall and accent tile selected so every floor contractor is bidding on the same material.

A3. Basis of design is around products manufactured by Mohawk, Calhoun, Georgia. See Section 09 05 15 – Color Design of selections for pricing.

Q4. Please provide instructions to obtain a digital set (PDF) of plans.

A4. Reference the below link:

<https://file-exchange.mdot.state.ms.us/dl/?f=26451660e4129d7e2ae15692c6869201e23656ec>

Q5. In reference to chain link partitions & gates, what is spelter coating?

Revised Answer: A5. ~~Plastic-coated~~ Galvanized

Q6. In Section 10 22 14 Chain Link Partitions & Gates, what does Class C spelter coating mean?

A6. Spelter coating means galvanizing the chain link fabric.