

Call 07 Construction of Byhalia Bulk Salt Storage Structure, known as State Project No. BWO-2218-47(001) / 503020301 in Marshall County.

Q1. I would like to view the specifications / plans for this project.

A1. Reference the following website:

<http://sp.mdot.ms.gov/Contract%20Administration/BidSystems/Pages/letting%20calendar.aspx> then click on the September 27, 2016 letting date then under Call 7 click to view the proposal or buy proposal/plans.

Q2. I am a Senior Project Manager for SteelMaster Buildings, LLC and will be sending quotations to contractors for the steel roof portion of this project. I have 3 questions: **1.** My standard roof height (above the concrete walls) is 14'-3.5". This is 1'-3.5" higher than shown on the specifications. Will this be acceptable? **2.** The specifications call for galvanized G-90 steel. We are using a much higher quality Galvalume Plus steel. Will this be acceptable? **3.** Is it possible to get a bidders list for this project? The contact information for SteelMaster Buildings is old and I would like to reach out to bidders. Current contact information for SteelMaster Buildings is: SteelMaster Buildings, LLC 1023 Laskin Road Suite 109 Virginia Beach, VA 23451 PH: 800-341-7007 Contact: Jerry Kain Extension: 8192 Email: wkain@steelmasterusa.com

A2. **1. & 2.** Yes, the specifications are minimum requirements, the structure can be taller and metal can be higher quality grade. **3.** The bidder's list can be found by clicking the link in Answer 1 above in the previous question and then click the September 27, 2016 letting date then under Call 7 click to view bid list. Also, it is noted that your contact information for SteelMaster Buildings is as follows: ***SteelMaster Buildings, LLC 1023 Laskin Road Suite 109 Virginia Beach, VA 23451 PH: 800-341-7007 Contact: Jerry Kain Extension: 8192 Email: wkain@steelmasterusa.com***