

Call 08 Replace Bridge No. 14.4 on SR 16 over Little Sunflower River, known as Federal Aid Project No. BR-0504-00(009) / 105836301 in Sharkey County.

Q1. The plan set on Bid Express does not contain the bridge plans; will you be posting a set that contains the bridge plans?

A1. Yes, the plans were reposted on 1/3/17 at 11:36 am.

Q2. Would MDOT waive the 1.5hr or 300 revolutions, if the mix design incorporated the use of a slump retaining admixture (Type S) to ensure the mix design, can still be placed without the addition of water to the batch.

A2. Yes. AASHTO M157 states that the 1.5 hours or 300 revolutions limit may be waived by the purchaser if the concrete is of such slump after the 1.5 hour time or the 300 revolutions limit has been reached that it can be placed without the addition of water to the batch.

Q3. Can you provide us with the as-built plans for the existing bridge as well as the bridge inspection report.

A4. They can be downloaded here: <https://file-exchange.mdot.state.ms.us/dl/?f=60b5389634cc165a514d2f5f77843f0d6eb32d6c>