

Call 07 Mill and Overlay SR 21 to Steele and SR 35 to SR 21, known as Federal Aid Project Nos. STP-0045-01(015) & STP-0023-02(060) / 107433301 & 302 in Scott County.

Q1. 1. Can traffic run on the milled surface of the side roads and crossovers?

A1. Yes.

Q2. Where SR 35 intersects US 80, will there be any paving east or west on US 80? There is no typical section showing any paving on US 80.

A2. There is no paving east or west on US 80. However, the ramps will be milled and overlaid at this intersection to the existing joints (at the island nose points), as directed by the Engineer.

Q3. What is the MRI category on this project?

A3. SR 35 will be Category B and SR 21 will be Category C.

Q4. What is the maximum lane closure length allowed for work on SR 35 and SR 21?

A4. One (1) mile.