

**Call 05 Bridge Replacement on SR 448 between Benoit & Shaw, known as Federal Aid Project No. STP/EXB-0610-00(017) / 100444301 in Bolivar County.**

Q1. What is the thickness of the concrete bridge mats?

A1. There is not a specified thickness. The thickness will be governed by which product is selected as shown on Sheet 8003 of the Bridge Plans.

Q2. The pay items list reference SP 907-832-PP003 for the Concrete Mat. I do not see this special provision in the proposal. Is this going to be in an upcoming addendum?

A2. No, this is a “per plans” pay item which does not require a Special Provision. Requirements for Concrete Bridge Mat can be found on Sheet 8003 of the Bridge Plans.