

Call 04 Bridge Painting on I-59 Bridge Nos. 10993, 10994, 11962 & 11963, known as Federal Aid Project Nos. BR-0059-01(119) / 107567301 & BR-0059-02(109) / 107568301 in Forrest & Jones Counties.

Q1. Unable to locate working hours for this project. Are there any time restrictions on work days/hours?

A1. See upcoming addendum.

Q2. According to SP 907-845-1, page 101; 907-845.02.6 speaks of a Class 3 rust preventative compound, hot applied. We are not familiar with this material and since it's a special provision, information cannot be found on this material. Also, unable to locate a rust preventative compound on the approved materials list. Can you please elaborate on the compound, who produces it, location of application, and application process? Thank you.

A2. The rust preventative compound shall meet the requirements of Military Specifications MIL-C-11796C. Technical data sheets for the Contractor's elected product shall provide the application process. Please refer the section 907-845.03.8.1 of proposal for locations the rust preventative compound is to be used.

Q3. Are we safe to assume that the rust preventative material is not needed on these bridges either?

A3. Yes.

Q4. Are there any plans or as-builts available for this project?

A4. The link below will take you to the plans and standards:

<https://file-exchange.mdot.state.ms.us/dl/?f=be62f34e7b18a31ce1a464c9c7e1d0b6e3709e82>