

Call 09 Renovate Existing HVAC & Lighting at the District Material Lab, known as State Project No. BWO-3074-82(004) / 503088301 in Yazoo County.

- Q1. What do we do with the existing fire alarm system after taking down existing fire alarm system in sheet rock and lay in ceilings and trying to get it rewired and hooked up? You could supply new system with warranty. Do we need to price supplying new system?
- A1. Per NFPA 90A, duct smoke detectors are required in the supply and return sides of units over 2000 cfm. This is indicated in the controls diagram portion of the drawings. Per specifications pages 23 01 70 - 3 and 23 09 60 - 4, new devices and cabling shall be provided and installed per code and tied into existing fire alarm panel.