

Call 01 Overlay approximately 7 miles on SR 63 from George CL to Sally Parker Rd, known as Federal Aid Project No. NH-0002-01(050) / 107645301 in George County.

Q1. Will the entire area of the crossovers be leveled or just the turn lanes and radius?

A1. The entire area of the crossovers will be leveled.

Q2. **1.** Will the final lift of asphalt be 1.25" or 1.5"? Both are referenced in the scope of work.
2. Is there a base repair schedule showing the location and approximate size of each base repair?

A2. See upcoming addendum.