

Call 01 Emergency Slide Repair on SR 178 between Auburn Road and SR 371, known as Federal Aid Project No. STP-2838-00(006) / 107794301 in Lee County.

Q1. Will you all allow for rain days on this project from the Notice to Proceed date to the completion date?

A1. No.

Q2. **1.** Who is responsible for the Construction Staking? **2.** In the event the 14 x 89 steel piling are driven out of tolerance, what will be the procedure for correcting?

A2. **1.** The Department will be responsible for construction staking. **2.** A three (3") tolerance, instead of one (1") as shown in the plans, will be allowed for this project. The Contractor will be expected to drive the piles within the three (3") tolerance.

Q3. Does this project require the asphalt, concrete, and excess dirt be disposed of in a rubbish pit?

A3. No. However, materials removed from the project shall be disposed of in accordance with Subsections 104.05 and 107.23 of the Standard Specifications.