

**Call 10 Overlay approximately 3 miles of SR 26 from the W ROW of SR 63 to the Junction of SR 198, known as State Project No. MP-6026-20(009) / 306429301 in George County.**

- Q1. **1.** Will a superelevation chart with slope percentage by station number be provided by the project engineer prior to leveling? **2.** Will traffic rated composite riser rings be allowed for manhole and water valve adjustments?
- A1. **1.** The existing cross slopes will be matched in the field as directed by the Engineer. **2.** The Contractor should refer to Subsection 613.03.1 of the Standard Specifications and the Department's APL which allows LADTECH HDPE Manhole Adjusting Rings to be substituted.