

**Call 15 Construction of New Albany Headquarters Building, Equipment Shed, and Site Improvements, known as State Project Nos. BWO-1195-73(001), BWO-1197-73(001), & LWO-1031-73(003) / 5030753010, 3011, & 3020 in Union County.**

- Q1. Are pre-bid substitutions allowed? If so, what is the procedure for submitting a product for consideration?
- A1. No. Please refer to Section 01 25 00, "Substitution Procedures", beginning on Page 82 of the Proposal.
- Q2. Will the MDOT consider classifying any of the pay items for this project as Specialty Items?
- A2. No.
- Q3. At the existing site there seem to be 3 buildings that are existing. Are those supposed to be removed in this contract or will those be removed prior to work?
- A3. They will be removed prior to the Notice to Proceed date in the proposal.
- Q4. Does the reinforcing steel in the 8" Plain Cement Pavement, Broom Finish get paid in the Reinforcing Steel pay item or is it absorbed in the Plain Cement Concrete Pay item?
- A4. The Plain Cement Pavement does not have reinforcement. It will be located at the Existing Equipment Shed as noted in Footnote #9 on Working Number T103, Sheet 4 and Working Number C3, Sheet 7 of the Contract Plans. Reinforced Concrete Paving shown on Working Number S101, Sheet 15 of the Contract Plans should be included in Pay Item 907-242-A001, Construction of Shop Building, Lump Sum, as noted.