

**Call 03 Bridge Preservation on US 278 over Fourmile Creek (Bridge Nos. 78.9A & 78.9B),  
known as Federal Aid Project No. BR-0070-04(025) / 107639301 in Lafayette County.**

- Q1. The FRP details and table on sheet 8019 appears to have inadvertently omitted the minimum ply thickness. This is needed to enable the Contractor to select the correct carbon fiber fabric. Most commercially available FRP systems have either a 0.020" and 0.040" ply thicknesses. For this application, it appears the Engineer intended to use 0.020" ply thickness, but omitted from the table.
- A1. See addendum.