

**Call 07 Bridge Joint Repairs on 6 Bridges, known as Federal Aid Project No. STP-9999-05(037) / 107882301 in Noxubee County.**

Q1. Some of the joints on these bridges measure between 3 and 4 inches wide. If the joint is larger than 2 ½", will the Contractor be required to build the joint back to 2 ½" or smaller?

A1. No. The Contractor will just be required to obtain and install the proper sized pre-formed joint material as per the manufacturer's recommendation.