

SECTION 905 -- PROPOSAL (CONTINUED)

I (We) hereby certify by digital signature and electronic submission via Bid Express of the Section 905 proposal below, that all certifications, disclosures and affidavits incorporated herein are deemed to be duly executed in the aggregate, fully enforceable and binding upon delivery of the bid proposal. I (We) further acknowledge that this certification shall not extend to the bid bond or alternate security which must be separately executed for the benefit of the Commission. This signature does not cure deficiencies in any required certifications, disclosures and/or affidavits. I (We) also acknowledge the right of the Commission to require full and final execution on any certification, disclosure or affidavit contained in the proposal at the Commission's election upon award. Failure to so execute at the Commission's request within the time allowed in the Standard Specifications for execution of all contract documents will result in forfeiture of the bid bond or alternate security.

Bidder acknowledges receipt of and has added to and made a part of the proposal and contract documents the following addendum (addenda):

ADDENDUM NO.	<u>1</u>	DATED	<u>11/15/2018</u>	ADDENDUM NO.	_____	DATED	_____
ADDENDUM NO.	<u>2</u>	DATED	<u>11/20/2018</u>	ADDENDUM NO.	_____	DATED	_____
ADDENDUM NO.	_____	DATED	_____	ADDENDUM NO.	_____	DATED	_____

Number	Description
1	Revised NTB No. 1192; Amendment EBS Download Required.
2	SP 907-242, Revised Section 00 91 13; Amendment EBS Download Required.

TOTAL ADDENDA: 2
(Must agree with total addenda issued prior to opening of bids)

Respectfully Submitted,

DATE _____

Contractor

BY _____
Signature

TITLE _____

ADDRESS _____

CITY, STATE, ZIP _____

PHONE _____

FAX _____

E-MAIL _____

(To be filled in if a corporation)

Our corporation is chartered under the Laws of the State of _____ and the names, titles and business addresses of the executives are as follows:

_____	President	Address
_____	Secretary	Address
_____	Treasurer	Address

The following is my (our) itemized proposal.

BWO-7145-43(001)/ 503007301000, BWO-7146-43(001)/ 503007302000 & LWO-7067-43(002)/ 503007303000
Lincoln County(ies)

Revised 01/26/2016

MISSISSIPPI DEPARTMENT OF TRANSPORTATION

ADDENDUM No. 1

SECTION 00 91 13

DATE: November 20, 2018

PROJECT: BROOKHAVEN PROJECT OFFICE & OPEN
EQUIPMENT SHED IN BROOKHAVEN, LINCOLN
COUNTY, MISSISSIPPI

PROJECT NUMBERS: BWO-7145-43(001) 503007
BWO-7146-43(001) 503007
LWO-7067-43(002) 503007

PART 1 - GENERAL

1.01 DESCRIPTION: Bidders are hereby advised that the following changes are to be made to this Contract.

1.02 DRAWINGS

- A. Sheet No. 3, Life Safety Information Title has been revised to read "LIFE SAFETY INFORMATION AS PER IBC 2015.
- B. Sheet No. 55, Under CODE NOTES, the code references 2006 International Fire Code and 2012 International Building Code have been revised to read "2015 International Fire Code and 2015 International Building Code".
- C. Sheet No. 37, Detail 1/A401-A, keynote indicating plastic laminate countertop is incorrect, the note should indicate a solid surface countertop, see Details B1 and B2 on Sheet A404-A.
- D. Sheet No. 40, All plastic laminate countertop edges to be PVC T-Mold as stated in specifications.
- E. Drawings: All handrails noted on drawings to be Aluminum handrails as stated in specifications.
- F. Sheet No. 30, Detail 1/A103-A, Indicates Wall cabinets above copier, (2) Wall cabinets above, 30"H x 30" W x 1'-0" D and Shelving units in Closet 118, (2) Shelving Units, Adjustable shelves, 7'-0" H x 1'-9" W x 1'-0" D.
- G. Drawings: Electrical contractor shall provide and install properly sized circuit to preheat coil associated with FCU-OA. Circuit is to originate from panel MDP1 and be routed overhead to FCU-OA. See Mechanical plans (sheets 52 & 53) for more information and location.

1.03 SPECIFICATIONS

- A. Section 01 10 00 – Summary, 1.01 Work Covered By Contract Documents, under paragraph C. Contractor’s Duties, Add paragraph, Utilities: Contractor to coordinate with local utility companies for installation and pay for all costs incurred thereby. Excluding AT &T service to site.
- B. Section 13 34 17 – Pre-Engineered Buildings, 2.04 Metal Roof Panels, A. Standing-Seam Metal Roof Panels should be revised to read “A. Metal Roof Panels”.
- C. Mechanical specifications identify multiple piping materials for waste and vent piping. Contractor shall be allowed to use PVC in all cases for above grade waste and vent piping.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION (Not Used)

END OF SECTION