

Call 04 Scrub Seal and Overlay approximately 10 miles of SR 13 from JCT US 84 North to Simpson County Line, known as Federal Aid Project No. STP-0037-01(062) / 107801301 in Jefferson Davis County.

Q1. What order will the widening take place and will it be allowed to go down in more than 1.5" Lifts?

A1. The widening will be placed with the surface lift. It will be 4-1/2" thick for the 2' wide trench.