

**Call 20 Mill & Overlay approximately 1 mile of SR 878 through the Town of Walnut Grove, and 2 miles of SR 492 through the Town of Walnut Grove, known as State Project Nos. MP-5878-40(001) / 306660301 & MP-5492-40(003) / 306660302 in Leake County.**

Q1. 1.) There are several concrete handicap ramps on 492 @ town square. Will these have to be removed and replaced? 2.) On 878 road presently closed for utility work. Will this work be completed by NTP and will this work affect the project?

A1. 1.) No, only curbs that are damaged during installation of cross drains will be replaced. 2.) The utility work is expected to be completed prior to the Notice to Proceed and will not affect the project.

Q2. Bid Item 202-B007 has 1123 SY on the Proposal Sheet No. 2. The schedules show only 23 SY for the cross drain and pipe replacement. Where is the additional 1100 SY?

A2. It is for the removal of the existing guardrail pads on SR 492 as referenced on Page 75 of the proposal.