

**Call 09 Emergency Bridge Repair on SR 184 over Dry Swamp Creek, Bridge No. 153.9, known as Federal Aid Project No. ER/BR-2173-00(002) / 102521301 in Jones County.**

- Q1. The power line on the north side of the bridge in its current location does not provide the clearance required per OSHA to construct the bridge, please confirm that the power line will be relocated prior to construction. The utility line on the south side of the bridge does not allow you access adjacent to the bridge required for construction. Please confirm that the utility line will be relocated prior to construction.
- A1. The power lines along the northern right-of-way will remain in place and either be shielded or de-energized during construction. The utility lines along the southern right-of-way will remain in place.
- Q2. After reviewing the project plans and field conditions, it appears the existing bridge will need Type "C" bridge end sections in lieu of Type "I" bridge end sections. Please advise.
- A2. Type "I" bridge end sections will be required.