

Call 11 Intersection Improvements on SR 9 at SR 341, known as Federal Aid Project No. HSIP-0050-01(033) / 106858301 in Pontotoc County.

- Q1. After a site visit and reviewing the traffic control plans, the safety of the public and the contractor is critical. It doesn't seem drums are sufficient. Was it ever discussed to use concrete barriers in lieu of plastic drums?
- A1. The work will be performed with drums as indicated in the contract plans. The Contractor will be required to bring the shoulders to the conditions shown on Working Number TCP-16, Sheet Number 6366, before leaving the project each day. Lane closures and flaggers should be used as each condition dictates.
- Q2. After visiting the site, I do not see where there is actually 10 acres of clearing and grubbing to be performed. Can you specify how this quantity was calculated?
- A2. See addendum.