

Call 02 Slide Repair on SR 9 approximately 8.90 miles South of the Webster County Line, known as Federal Aid Project ER-0050-01(038) / 108457301 in Choctaw County.

Q1. Notice to Bidders #2214 doesn't state the DBE requirement. What will be the DBE requirement on this project?

A1. An addendum will be forthcoming to address the DBE requirement, if any.

Q2. Can sheet pile be used in the place of H pile for this project?

A2. No.

Q3. The typical section on sheet 70 of the proposal (plan sheet 4, working number TS-1) shows the overall shoulder width at 3' and variable. However underneath that dimension are two dimensions of 2' each. Should the overall shoulder dimension be 4'?

A3. The 2' lines below it were meant only for the stone and not for shoulder width. 3' (and variable) is the correct shoulder width.