

Call 04 Slide Repair on US 61 approximately 3 miles North of Adams County Line (Westside only), known as Federal Aid Project No. STP-0009-01(141) / 107786301 in Jefferson County.

Q1. Will the Contractor be allowed to vibrate the piles?

A1. Pile placement by vibration will be allowed as long as the required tip elevations can be achieved. If pile placement by vibration cannot reach the required tip elevations, the Contractor will be required to change the pile driving system.

Q2. Plan Sheet No. 5 mentions the repair is to be completed in 50-foot sections to maintain stability. Does this apply to the entire project, including clearing & grubbing and pile installation?

A2. No, the 50-foot limit applies to Items 1 through 7 under the Phase 2 Construction Sequence shown on Sheet 5.