

**Call 06 Railroad Crossing Improvements on SR 706 in Sidon, known as Federal Aid Project No. STP-9999-03(367) / 107891301 in Leflore County.**

Q1. There is no clear scope or drawings for this project. Can this be clarified or addressed before letting?

A1. Plans are now available for purchase through ShopMDOT.

Q2. The summary of quantities sheet shows erosion control item quantities on erosion control sheets ECP 3 & ECP 4. The sheets in the plans do not show where any of these items are to be placed. Please advise if any of these items will encroach on the railway ROW.

A2. Sheets ECP-3 and ECP-4 are the empty plan sheets for the contractor to use for their ECP. The Contractor determines the type and placement of erosion control items with the concurrence of the Engineer.