

Call 02 Bridge Rail Replacement on US 49 N to I-20 W Flyover (Bridge No. 30), known as Federal Aid Project No. NHPP-0008-03(057) / 108137301 in Rankin County.

- Q1. In the sections of the rail that will contain an 18" wide Pullbox on the inside face of the rail. Will we be permitted to cut the vertical reinforcement (spaced at 5 1/2") to allow room for the pullbox?
- A1. No. Please refer to "Notes on Railing Reinforcement" and the supplemental reinforcement details on Sheet 8019 of the plans.
- Q2. Is US 49 included in the lane closure restrictions shown in NTB 2987?
- A2. Yes.
- Q3. The railing steel is tie-in-place. Would the Department consider a mesh alternative in place of tying?
- A3. A mesh alternative will not be allowed for this project.