

**Call 05 Bridge Repair on I-10 over the Pascagoula River (Bridge No. 65.4B), known as Federal Aid Project No. NHPP-0010-01(169) / 108043302 in Jackson County.**

Q1. Can the CRR reinforcing be epoxy rebar meeting the requirements of 711.02.8 or will it have to meet the requirements for 711.02.9 for corrosion resistant reinforcement?

A1. The rebar should meet the requirements for 711.02.9 for corrosion resistant reinforcement.