

**Call 05 Bridge Repair on I-10 over the Pascagoula River (Bridge No. 65.4B), known as Federal Aid Project No. NHPP-0010-01(169) / 108043302 in Jackson County.**

Q1. In the plans, it says reinforcing steel shall be minimum Grade 60 and shall be CRR. In the Red Book, CRR is Grade 100 and meets ASTM A 1035 CS, and grade 60 would be the stainless steel reinforcement. Which one is correct?

A1. Both Grade 60 Stainless Steel and Grade 100 CCR are acceptable.