

**Call 01 Sidewalk Replacement on US 90 between Fort Henry Avenue & Trautman Avenue,
known as Federal Aid Project No. ER-0003-01(211) / 108763301 in Harrison County.**

Q1. 1.) Will there be any compaction requirements for existing subgrade material under concrete sidewalk to be removed and for the excavated material from footing excavation that can be utilized for base material? 2.) If any additional material is needed for base material, can the material between sidewalk and highway be utilized for what base material may be needed? 3.) Is reinforcing material to be utilized in the 4" thick section of sidewalk?

A1. 1.) Refer to Subsection 608.03.2 of the Standard Specifications. 2.) Yes. 3.) Yes.

Q2. Can fiber reinforcement be used in the sidewalk in lieu of wire mesh?

A2. Yes.