

Call 04 Safety Improvements on I-110 Southbound at US 90 Westbound, known as Federal Aid Project No. HSIP-0110-01(030) / 108488301 in Harrison County.

- Q1. On Working Number ICWS-1 Sheet 8 it shows installing power to the 4-phase base mounted cabinet using the existing meter installing a breaker. This meter is not capable of accepting a breaker it is a meter only. The lighting panel that it powers is only powered up at night through a contactor and photocell. How do we now install power to the new base mounted cabinet?
- A1. The Contractor is to install a new auxiliary breaker box and breaker. Cost is to be absorbed.