

Call 12 Slide Repair on SR 3 approximately 3 miles north of Satartia, known as Federal Aid Project No. STP-0072-02(031) / 108506301 in Yazoo County.

Q1. Regarding the hydrojetting: is it just the 1½" plastic pipe both slotted and non-slotted that is to be hydrojetted or all the pipe shown on sheet 6?

A1. Hydrojetting is only required on the 1½" slotted and non-slotted pipe.