

**Call 01 Bridge Repair on SR 28 over Jones Creek (Bridge No. 43.0), known as Federal Aid Project No. STBG-0013-01(019) / 109301301 in Copiah County.**

Q1. Can we request as-builts for this project?

A1. The plans can be downloaded at the following link: <https://file-exchange.mdot.state.ms.us/dl/?f=ce1b102a5ba4635edd6c8701dbf9789efd4c70c9>

Q2. In regard to note on page 75 of the proposal, "Concrete spalling to be patched according to the locations on this sheet. Beam should be restored to original dimensions." Please confirm that all work related to patching beam concrete spalling is paid under pay item 907-824-A003: General Epoxy Repair.

A2. As per Subsection 907-824.05, Basis of Payment, epoxy mortar repairs necessary prior to the installation of the FRP Wrap are to be included in the price of the FRP Wrap.