

Call 12 Construction of a Roundabout on US 51 at Main Street, known as Federal Aid Project No. NHPP-2920-00(015) / 107438301 in Tate County.

- Q1. 1.) Sheet #4001 Keyed note #5. Note is calling to bore 2" sch 80 HDPE with (3) #2's. Should this have its own pay item? 2.) What size does the underground junction box need to be? 3.) What is the size of the concrete pad at the pole foundation and underground junction box?
- A1. 1.) It will be absorbed in the cost of the Secondary Power Controller. 2.) The junction box shall be sized per the NEC requirements. 3.) The concrete pad shall be flush with grade, 6" deep. Additional information can be downloaded at the following link. <https://file-exchange.mdot.state.ms.us/dl/?f=1263b979bd304d9b9f94b6cc76424c965aa373e1>