

**Call 06 Interchange Reconstruction on I-10 at Diamondhead, known as Federal Aid  
Project No. NHPP-0010-01(161) / 107509301 in Hancock County.**

- Q1. Plans/Specs show to remove both armor joints on the bridge end and repair with elastomeric concrete. Should there be a pay item for that item? 907-824-PP007 Bridge Repair, Elastomeric Concrete?
- A1. It is estimated that 2 CY of elastomeric concrete will be required for this work and it will be considered an absorbed item.