


MND-756
Rev. 2007

Mississippi Department of Transportation
Clearing and Pruning Limits For Above Ground
Utility Highway Crossings For Electric Power Lines

Application and Plan for Proposed _____
on Highway No. _____ in _____ County, as
submitted by _____ of _____

Sheet No. _____ of _____
Project No. _____
Permit No. _____



500 KV LINE CLEARING LIMITS
230 KV LINE CLEARING LIMITS
161 KV LINE CLEARING LIMITS
115 KV LINE CLEARING LIMITS
110 KV LINE CLEARING LIMITS
69 KV LINE CLEARING LIMITS
44 KV LINE CLEARING LIMITS
23 KV LINE CLEARING LIMITS

100' RT. & LT.
65' RT. & LT.
50' RT. & LT.
50' RT. & LT.
50' RT. & LT.
40' RT. & LT.
25' RT. & LT.
25' RT. & LT.

The clearing and pruning limits indicated on this form are the maximum widths of trees and other vegetation allowed to be removed. However, special cases may arise where additional clearing and pruning would be necessary to better fit field conditions. If so, the District Engineer or his/her authorized designee may allow an adjustment in the subject limits on a case by case basis. Any modification of the limits must be noted on the appropriate permit form(s).